

- ALL TEST COCKS MUST BE PROVIDED WITH PCV PLUGS.
- A CITY APPROVED VALVE IS REQUIRED BETWEEN THE SUPPLY MAIN AND THE VAULT.
- VAULT SHALL BE PLACED ON PRIVATE PROPERTY AT PROPERTY LINE.
- FOR COMMERCIAL BUILDINGS THAT HAVE NO SET BACK REQUIREMENTS, THE DCDA CAN BE MOUNTED ON THE WALL ADJACENT TO THE ROW WHERE THE LINE TIES INTO THE MAIN. (SEE DETAIL E 7.19)

VAULT SIZES

METER SIZE AND TYPE	APPROXIMATE EQUIP DIMENSIONS				MINIMUM INSIDE VAULT DIMENSIONS (EXCLUDES SIAMESE CONNECTION)			
	Α	В	С	D	LENGTH	WIDTH	HEIGHT	
4" X 3/4"	2'-9"	1'-1"	0'-6"	4'-3"	10'-0"	5'-0"	6'-6''	
6" X 3/4"	3'-9"	1'-2"	0'-8"	5'-6"	11'-0"	6'-0"	6'-6''	
8" X 3/4"	4'-5"	1'-4"	0'-9"	6'-4"	12'-0"	6'-0"	6'-6''	
10" X 1"	6'-0"	1'-8"	0'-11"	8'-6"	14'-6"	7'-0"	6'-6''	



CITY OF EDMONDS										
REVIS			STAN	IDARD	DF	TAII				
APPROVED BY	DATE		O 17 (1			. ,				
D. GEBERT	6/16/03		DOUBLE CHE	CK DETECTOR		-	' -			
D. GEBERT	10/6/03			(CUMMERCIAL	_MULTH	FAMILY)				
D. GEBERT	10/6/03	DATE		SCALE	DV	VG NO.	F7.0			
D. GEBERT	4/2/07		7/24/01	NTS	-		E7.8			

INDOOR VERTICAL INSTALLATION